

PROJECT CHECKLIST

To initiate a project, please review this checklist to certify that plans are submitted in accordance with the latest Sacramento Suburban Water District Improvement Standards and Technical Specifications.

SSWD Submittal Requirements

- Completed Water Service Application(s)
- Completed Water Main Extension Application (if required)
- Two sets of plans in hard copy
- Plans in electronic format (PDF and DWG plus all externally referenced files)

Plans-Cover/General Sheets

- Contact information for project developer
- Index of Sheets
- Vicinity Map
- APN Numbers
- Fire Department Approval Signature Block
- SSWD Approval Signature Block
- Legend of Symbols
- USA Contact Number - Call 48 hours prior to dig
- SSWD General Notes

Water/Utility Plan Sheet

- North arrow
- Scale of plan
- Street names and widths
- Engineer's stamp, signature and license number (for final approval)
- Entire project, subdivision or parcel
- Adjacent subdivisions with lot lines and lot numbers
- Right-of-Way with lines properly dimensioned
- Topography with all pertinent topographic features
- Bench marks and datum with location, description and elevation
- Existing utilities
- Utility horizontal/vertical clearance information
- Existing easements with recordation information
- Proposed easements
- Construction notes referencing SSWD Standards and Details
- Separate domestic, irrigation, and fire service connections
- Appropriate offset of services from property lines
- SSWD Standard Detail #1
- Adequate separation from other utilities
- Adequate connection details
- Appropriate pipe cover
- All water mains shall be ductile iron pipe - Class 350

Backflow Prevention Devices

- All fire services shall have double detector check assembly per Sacramento County Standard Detail # 8-8C
- All commercial, irrigation and residential services (5 units or more) shall have a reduced pressure backflow device per Sacramento County Standard Detail # 8-8A or 8-8B.